

NOTICE TO BIDDERS
ADDENDUM #1
TOWNSHIP OF RANDOLPH, MORRIS COUNTY, NEW JERSEY
MUNICIPAL BUILDING LED SIGN
BID OPENING DATE – WEDNESDAY, JULY 10, 2013, 11:00 A.M.

NOTICE IS HEREBY GIVEN that sealed bids for the **MUNICIPAL BUILDING LED SIGN** for the Township of Randolph, County of Morris, State of New Jersey will include an acknowledgement of ADDENDUM #1. The ACKNOWLEDGEMENT OF RECEIPT OF CHANGES TO BID DOCUMENTS FORM included in the bid specifications must be completed. Addendum #1 consists of changes, clarifications, and additions to information in the bid specifications. The Addendum shall become part of the original specifications and is to be attached thereto.

All vendors who obtained the bid specifications on or prior to this date of notice have been provided this Addendum as required.

June 14, 2013
Elizabeth Crescibene, RPPO, QPA
Purchasing Agent

ADDENDUM #1

The following comments are provided in response to written questions concerning the Municipal Building LED Sign Project:

Q1 – Can you please email a photo of the existing sign?

A1 – A photo of the existing sign follows. If you want the photo of the existing sign to be emailed to you, please provide an email address to Liz Crescibene at lcrescibene@randolphnj.org

Q2 – Can we scrap the old brick and make a new brick veneer? This would be cheaper and newer looking than making a veneer out of the old brick.

A2 – The contractor may use new brick material in lieu of using material taken from the existing sign, however the material must match the brick on the existing building and the material is subject to the prior approval of the Township Engineer. All new brick samples must be submitted to the Township Purchasing Agent, Liz Crescibene, Township of Randolph, 502 Millbrook Avenue, Randolph, NJ 07869 no later than close of business on June 26, 2013 along with the manufacturer's name, product name, color, product number, etc. If any new brick material samples are approved for use in this project, bidders will be notified via another addendum issued no later than Friday, June 28, 2013. NO new brick material samples for approval will be accepted after close of business on June 26, 2013.

Q3 – Does the new sign have to go in the EXACT same spot as the existing sign we are removing? If it is to be in the same location, what is the size and type of foundation?

A3 – The sign does not need to be placed in the exact location of the existing sign. The new sign shall be within 5 feet of the existing sign. The demolition of the existing sign shall include its removal to 12"± below grade, backfilling, topsoil, seeding, fertilizer and mulch. The type of existing foundation is unknown, but it should be assumed to be concrete or concrete block.

RANDOLPH
TOWNSHIP
MUNICIPAL BUILDING

2013.06.14