

NOTICE TO BIDDERS
ADDENDUM #1
TOWNSHIP OF RANDOLPH, MORRIS COUNTY, NEW JERSEY
EVERDALE ROAD RETAINING WALL REPLACEMENT PROJECT – PH 2
BID OPENING DATE – FEBRUARY 17, 2017, 11:00 A.M.

NOTICE IS HEREBY GIVEN that sealed bids for the **EVERDALE ROAD RETAINING WALL REPLACEMENT PROJECT – PH 2** for the Township of Randolph, County of Morris, State of New Jersey will include an acknowledgement of ADDENDUM #1. The ACKNOWLEDGEMENT OF RECEIPT OF CHANGES TO BID DOCUMENTS FORM included in the bid specifications must be completed and returned with the bid package. The Addendum shall become part of the original specifications and is to be attached thereto.

This Addendum is being issued in response to a bidder question.

Q. "On the bid pricing sheet for Everdale Road Retaining Wall the traffic striping is listed at 5 inches wide. On the plans the traffic striping is listed at 6 inches wide. Please let me know which is correct so we can properly quote this bid item."

A. Traffic striping should be 6 inches wide.

Elizabeth Crescibene, RPPO, QPA
Purchasing Agent