

NOTICE TO BIDDERS
ADDENDUM #1
TOWNSHIP OF RANDOLPH, MORRIS COUNTY, NEW JERSEY
LIBRARY ADDITION
BID OPENING DATE – WEDNESDAY, SEPTEMBER 25, 2013, 11:00 A.M.

NOTICE IS HEREBY GIVEN that sealed bids for the **LIBRARY ADDITION** for the Township of Randolph, County of Morris, State of New Jersey will include an acknowledgement of ADDENDUM #1. The ACKNOWLEDGEMENT OF RECEIPT OF CHANGES TO BID DOCUMENTS FORM included in the bid specifications must be completed. Addendum #1 consists of changes, clarifications, and additions to information in the bid specifications. The Addendum shall become part of the original specifications and is to be attached thereto.

All vendors who obtained the bid specifications on or prior to this date of notice have been provided this Addendum as required.

September 16, 2013
Elizabeth Crescibene, RPPO, QPA
Purchasing Agent

ADDENDUM #1

The following comments are provided in response to written questions concerning the Library Addition Project:

Q1: In "INFORMATION FOR BIDDERS", "SUBMISSION OF BIDS", please clarify the meaning of "and submit their bid with the attached Contract Documents" i.e.: do drawings and written spec have to be submitted with proposal form, what constitutes the "Contract Documents" in this section?

A1: Only the proposal form and attachments need to be returned. The entire written spec and drawings do not need to be returned.

Q2: On drawing A-3 only (1) type D window is shown, on drawings A-8 (2) type D windows are listed.

A2: On Sheet A-8, on the window schedule there should be only one (1) type D window.

Q3: Drawing A-4 shows (2) roof top units, drawings H-1 shows only (1) roof top unit and H-3 on the schedule lists only (1) unit but the curb details state RTU 1 & 2.

A3: Quantity of rooftop units is one (1).

Q4: Is carpet 1 broadloom or carpet tile?

A4: Carpet 1 is carpet tile.

Q5: Could you please provide the name of the current fire alarm vendor.

A5: The current Ademco fire alarm system is being monitored by Protective Systems Services Company, Newton, NJ.

Q6: Regarding the openings into Room 118, the sizes on A-3, A-4 and S-1 are all different.

A6: The new openings into Room 118 to be 6'-0" and 10'-0" with 3'-0" of wall between openings. Lintel over 10'-0" opening to be W 8 x 24.

Q7: Are the door frames for doors 101-106 hollow metal or wood?

A7: Doors 101-106 to have hollow metal frames.