

NOTICE TO BIDDERS
ADDENDUM #1
TOWNSHIP OF RANDOLPH, MORRIS COUNTY, NEW JERSEY
FARM ROAD & ARNOLD DRIVE SANITARY SEWER PROJECT
BID OPENING DATE – JANUARY 12, 2022, 11:00 A.M.

NOTICE IS HEREBY GIVEN that sealed bids for the Farm Road & Arnold Drive Sanitary Sewer Project for the Township of Randolph, County of Morris, State of New Jersey will include an acknowledgement of ADDENDUM #1. The ACKNOWLEDGEMENT OF RECEIPT OF CHANGES TO BID DOCUMENTS FORM included in the bid specifications must be completed and returned with the bid package. The Addendum shall become part of the original specifications and is to be attached thereto.

This Addendum is being issued in response to a bidder's question.

Q1: I see in the Base Bid, item #14 is a pay item for 560 Square Yards of Concrete Sidewalk. Can you clarify that this number is accurate, and that this item is just to pay for what we have to restore from what's been disturbed by our work? Or are there portions of sidewalk on Farm Road and Arnold Drive that need to be removed and replaced with new sidewalk regardless of whether we disturb the existing sidewalk or not? If the latter is true, can you clarify on the plans which sections of sidewalk need to be replaced?

A1: The sidewalk removal and replacement quantity is for all existing sidewalk areas that are disturbed during the installation of the proposed sanitary sewer laterals for each residential property. We note that the unit for this sidewalk item (#14) should be 560 square feet (SF), not square yards (SY), or about 40 sf per sanitary lateral connection. There are 14 proposed sanitary laterals with sidewalk crossings and one other proposed sanitary lateral in the grass area only. Bidders are to change the "SY" and "Square Yard" on the Schedule of Prices page for Item #14 to "SF" and "Square Feet".

Elizabeth Crescibene, RPPO, QPA
Purchasing Agent